

# Performance Data Sheet

## VIQUA Validated Class B Systems

Model: D4-V

### NOTICE

- This Class B system or component conforms to NSF/ANSI 55: Ultraviolet Microbiological Water Treatment Systems for the supplemental bactericidal treatment of disinfected public drinking water or other drinking water that has been tested and deemed acceptable for human consumption by the state or local health agency having jurisdiction. The system is only designed to reduce normally occurring non-pathogenic, nuisance microorganisms. Class B systems are not intended for treatment of contaminated water.
- While testing was performed under standard laboratory conditions, actual performance may vary.

Water quality is extremely important for the optimum performance of your UV system. Consult your local authority for water chemistry accommodations in your area.

Operating Parameters	
Electrical Requirements	100-240V 50/60Hz 1.0A Max
Maximum operating pressure	125 PSI (862 kPa)
Minimum operating pressure	4 PSI (27.5 kPa)
Ambient air temperature	0°C - 40°C (32°F - 104°F)
Rated flow for NSF/ANSI Std 55, Class B	8.9 gpm (33.7 lpm) (2.02 m <sup>3</sup> /hr)
<b>Note:</b> The system must be installed indoors only, according to local plumbing codes on the cold water line.	

## Replacement Parts

Description	Part Number
UV Lamp	602805
Quartz Sleeve	602732
Controller	650733R-002

Owners should view the UV system periodically for displayed status feedback (Lamp End of Life alarm). During annual lamp replacement, it is advised to properly inspect and clean the Quartz Sleeve to ensure optimum performance of the UV system. Contact your dealer if service or replacement parts are required.

**Note:** Required replacement interval of ultraviolet lamp is 1 year.